

OPTCL



(Approved by OERC vide Letter No. OERC-Engg-5/98 (Vol.XX)/ 70 dt. 14.01.2020)

PERFORMANCE OF THE TRANSMISSION SYSTEM OF OPTCL FOR 2018-2019

[This report is prepared in pursuance of Licence Condition 16.7 & Clause 13.7 of Appendix-4B of the OERC (Conduct of Business) Regulations, 2004]

SALIENT FEATURE ON PERFORMANCE OF TRANSMISSION SYSTEM OF OPTCL DURING THE YEAR 2018-19

1. Procurement of Power:

Source	Commission's Approval (MU)	Actual Drawl for the State Consumption (MU)	Remarks
OHPC	5881.74	6154.32	
Thermal(TTPS+OPGC)	6288.89	5966.83	
CPP	0	468.67	
Renewable Generation	1102	806.59	
IPP	7889.53	2865.67	
EREB	5641.65	9780.376	
Net Banking +IEX+OA		226.238	
Total	26803.81	26268.694	State's Maximum and Minimum demand was 5427 MW and 3186 MW respectively

2. Voltages profile of Major Grid Sub-stations

Allowable Range (245-198 KV)

Sl. No.	Name of the 220/132 kV Grid Sub-station	Maximum Voltage in kV	Minimum Voltage in kV
1	ATRI	236	208
2	Balasore	236	201
3	Bhadrak	239	204
4	Bhanjanagar	238	213
5	Bidanasi	240	213
6	Budhipadar	234	201
7	Chandaka	235	206
8	Duburi	238	212
9	Jaynagar	240	221
10	Joda	235	209
11	Katapalli	235	205
12	Lapanga	236	204
13	Laxmipur	240	220
14	Mendhasal	238	208
15	Meramundai	229	216
16	Narendrapur	241	204
17	Paradeep	235	204
18	Sadeipali	232	200
19	Tarkera	248	220
20	Theruvali	236	210

Allowable Range (145 -122 KV)

Sl. No.	Name of the 132/33 kV Grid Sub-station	Maximum Voltage in kV	Minimum Voltage in kV
1	Cuttack	141	115
2	Berhampur	145	119
3	Puri	138	116
4	Khurda	139	122

3. System Interruptions due to Major Incident:

INTERRUPTION DUE TO MAJOR INCIDENT			
Incident Duration of Interruption No. of Interruption	Duration of Interruption (Hrs:Min:Sec)	No. of Interruption	Remarks
Snapping of Jumper / Conductor / Earth wire	19:51:00	39	The duration of interruption indicated above is the sum total of interruptions occurred at different areas(S/s) during the year. However there was no total blackout
Insulator Failure	16:53:00	25	
Bursting of CT / PT	4:06:00	11	
Breaker Problem	0:00:00	0	
Major System Disturbance	12:09:00	9	
Failure of LA	7:28:00	10	
Others	81:35:00	172	

Note: Issued in the Public interest. Detailed report on Performance of Transmission System of OPTCL is available in SLDC website i.e., www.sldcorissa.org.in

COMMISSION'S OBSERVATION ON THE PERFORMANCE OF THE TRANSMISSION SYSTEM OF OPTCL FOR 2018-19

The salient features of the performance of transmission system of OPTCL for the year 2018-19 is given below and the detail information in support to that is available in SLDC website i.e., www.sldcorissa.org.in

A. Procurement of Power:

The Commission had approved the purchase of power by GRIDCO from various sources in the ARR & Tariff order for 2018-19 against which the actual performance have been indicated in the following table:

Source	Commission's Approval (MU)	Actual Drawl for the State Consumption (MU)	Remarks
OHPC	5881.74	6154.32	State's Maximum and Minimum demand was 5427 MW and 3186 MW respectively
Thermal(TTPS+OPGC)	6288.89	5966.83	
CPP	0	468.67	
Renewable Generation	1102	806.59	
IPP	7889.53	2865.67	
EREB	5641.65	9780.376	
Net Banking +IEX+OA		226.238	
Total	26803.81	26268.694	

There is an import of 1248.657 MU through power banking, open access, trading & IEX and export of 1152.737 MU (46.694 MU as sales to other utilities, 130.32 on account of deviation and 975.73 through trading, OA, banking & IEX export) during the FY 2018-19. Hence, in the said financial year GRIDCO has an export of 95.92 MU on this account. Further, the less drawal from TTPS and OPGC against approval of OERC are due to some long outages (TTPS :- # 1- 50 days 11 hours 51 minutes, # 2 - 63 days 14 hours 5 minutes, # 3 - 111 days 23 hours 39 minutes, # 4 - 82 days 17 hours 1 minute, # 5 - 74 days 6 minutes, # 6 - 87 days 15 hours 40 minutes ; OPGC : - # 1- 17 days 4 hours, # 2 - 28 days 16 hours 49 minutes) of their units and backing down. It is observed that there have been long outages in case of TTPS. Therefore, they need to be more cautious about it so that power supply plan of GRIDCO is not unduly affected.

2. During FY 2018-19 the daily peak demand touched at 5427 MW maximum on dt.23.08.2018 and a minimum of 3186 MW on dt.17.12.2018. The peak demand of 5427 MW in 2018-19 is about 912 MW higher than the peak demand experienced during the previous year 2017-18 (4515 MW). The total energy drawl is 26269 MU in FY 2018-19 against 25392 MU in FY 2016-17, which indicates the enhancement in electricity consumption of around 877 MU in the State.

B. Line Interruption:

3. OPTCL's system has faced aggregated Annual interruptions varying from 4 hours to 81 hours at different locations on account of conductor/jumper/earth wire snapping, insulator failure, bursting of Current Transformer/Potential Transformer, breaker problem, system disturbance, Lightening Arrester failures and others. However, OPTCL has claimed that it has arranged to maintain power supply without resorting to total power failure. The same effort has been made by OPTCL in maintaining uninterrupted power supply even in the event of generation failures. It has been reported about 3.5, 12 and 6 hours of load restriction during the first, second and third quarter respectively for the FY 2018-19 on rotation basis. The load restriction has been imposed to curtail the demand. OPTCL claimed that there was no black out experienced in the State during the FY 2018-19. OPTCL should find out latest technical methods for effective utilization of existing level transmission system to increase power transfer capacity, reliability avoiding RoW problem. OPTCL is required to maintain the system to ensure power supply without interruptions in any part of the State and ISGS of Eastern Region. The Commission expects OPTCL to have periodic O&M and R&M activities with provision of sub-station automation and also plan for a Disaster Resilient Transmission System to prevent the damage to a large extent during natural disaster. Further, OPTCL should maintain its transmission elements without overloading in consultation with DISCOMs and upgrade the system, wherever required.

C. Frequency Profile:

4. As per the provisions in Indian Electricity Grid Code Regulations, 2010, all users, SEBs, SLDCs, distribution licensee & bulk consumer shall take all possible measures to ensure that grid frequency always remains within 49.90 to 50.05 Hz band. OPTCL has experienced frequency as low as 49.59 Hz during 4th quarter and as high as 50.29 Hz during 4th quarter of FY 2018-19. DISCOMs should be coordinated to adhere to their drawl schedule in order to reduce their drawl from the grid during low frequency and maintain grid discipline.

D. Voltage Profile:

5. The EHT voltage, as per Regulations 3(1)(b) of Central Electricity Authority(Grid Standards) Regulations, 2010 should be in the range 122-145 kV for voltage at 132 kV, 198-245 kV for voltage at 220 KV and 380-420 kV for 400 kV level. OPTCL has however experienced 200 kV minimum and 241 kV maximum in its 220 kV system and 115 kV minimum and 145 kV maximum in its 132 kV system. As reported, the voltage level at few 132 KV S/Ss have been lower than the allowable limits. Therefore, OLTC of the power


transformers should be in healthy condition and all the field engineers should be trained to operate it during peak and low load condition to maintain voltage. Also, OPTCL should monitor the reactive drawl of DISCOMs from its grid S/S and wherever DISCOM draw excessive reactive load at low voltage condition, it shall take up with them for remedial measure.

E. Load Restriction:

6. M/s. OPTCL has claimed that the load restriction due to non-availability of the transmission capacity as ‘NIL’ which in turn indicates that during FY 2018-19 that OPTCL system availability was 100%. The projects already approved by the Commission and is under execution should be completed by OPTCL within the time schedule to avoid cost & time overrun. Simultaneously, OPTCL needs to avoid under loading of lines & resultant to losses and should conduct comprehensive system study before proceeding for any network expansion plan. There should be periodic audit of relay/protection system of transmission system/distribution system within the state for reliable operation of the system

F. Efficient Operation of Transmission System:

7. SLDC, being the apex body to ensure integrated operation of the power system of the state, should be responsible for optimum scheduling and dispatch of electricity within the state. Since, SLDC is responsible for carrying out real time operations for grid control and dispatch of electricity through secure and economic operation of state grid, its staffs are to be appropriately trained for efficient functioning of the centre. Recommendation of “SAMAST” should be implemented.




JHARKHAND

WEST BENGAL

CHHATTISGARH

BAY OF BENGAL



WEST ZONE

NORTH ZONE

SOUTH ZONE

LEGEND

DETAILS OF LINE	Existing	Proposed / U/C
765KV TRANSMISSION LINE		
Solar Projects		
400KV TRANSMISSION LINE		
220KV TRANSMISSION LINE		
132KV TRANSMISSION LINE		
HYDRO POWER STATION		
THERMAL POWER STATION		
GRID S/S & TRACTION S/S		
SWITCHING STATION / CGP / IPP		
BULK CONSUMER		
STATE BOUNDARY		
DISTRICT BOUNDARY		
ZONE BOUNDARY		
Solar Pooling Station	SPS	

ODISHA POWER TRANSMISSION CORPORATION LIMITED
Bhubaneswar


SCHEMATIC TRANSMISSION MAP OF OPTCL(EXISTING & PROPOSED)

Length in kms.

NOT TO SCALE

GRID DEMAND FOR THE YEAR 2018-19


[Total Drawal 26268.694 MU]



DAILY PEAK DEMAND (MW) EXCLUDING TRADING FOR THE YEAR 2018-19


Day	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18	Jan-19	Feb-19	Mar-19	Max	Min
1	3284	3610	4729	3990	4656	4519	4825	4329	4038	3632	3779	3794	4825	3284
2	4016	3877	4208	4050	4509	4663	5270	4235	3980	3646	3862	4344	5270	3646
3	4013	4303	4199	4065	4942	4772	5147	4236	3685	4109	3751	4252	5147	3685
4	3502	4421	4103	4112	5030	4377	5226	4291	3594	4059	3702	4217	5226	3502
5	3523	4554	4311	4062	4584	3973	5187	4394	3594	3820	3805	4036	5187	3523
6	3564	4436	4234	3910	4612	3800	5173	4471	3545	3746	3846	4014	5173	3545
7	3906	4692	4558	3887	4706	4824	5087	4388	3572	3833	3789	3919	5087	3572
8	3711	4542	4422	3895	4751	4786	5042	4522	3564	3496	3802	3926	5042	3496
9	3344	4237	4007	4035	5149	4867	4888	4385	3469	3569	3845	4117	5149	3344
10	3727	4103	4234	3938	4925	4440	4670	4324	3628	3683	3659	4006	4925	3628
11	3906	4007	4113	4284	5021	4554	4068	4160	3563	3633	3759	4317	5021	3563
12	3541	3855	4145	4330	4973	4475	4274	4190	3797	3672	3770	4125	4973	3541
13	3906	4105	3800	3955	4852	4470	4388	4275	3736	3530	3695	4092	4852	3530
14	3586	3330	4141	3767	4764	4349	4484	4144	3427	3505	4223	3999	4764	3330
15	3906	3721	4245	3713	4452	4434	4655	4191	3658	3626	4100	3863	4655	3626
16	3906	3609	4355	3407	4752	4186	4619	4142	3596	3711	3721	4232	4752	3407
17	3906	3438	4309	3936	5027	4266	4614	4186	3186	3604	3603	3685	5027	3186
18	3906	3728	4342	4003	4918	4550	4570	4189	3487	3664	3855	3993	4918	3487
19	4136	4203	4634	4196	4342	4553	4509	4199	3601	3674	3863	4181	4634	3601
20	3879	4593	4683	3677	4595	4175	4795	4214	3533	3616	3791	3980	4795	3533
21	4176	4190	4571	3257	4838	4291	4864	4140	3531	3685	3908	3971	4864	3257
22	4425	4537	3897	3669	5135	4708	4603	4122	3583	4027	4089	3700	5135	3583
23	4201	4345	4415	4246	5427	4854	4627	4114	3578	3888	4133	4074	5427	3578
24	4078	4466	4311	4090	5172	4810	4679	4159	3632	3771	4046	4124	5172	3632
25	4067	4310	4287	4174	5132	4398	4817	4133	3753	3693	3875	4212	5132	3693
26	3813	4330	4076	4107	4529	4239	4395	4192	3583	4058	3753	4587	4587	3583
27	3805	4327	3810	4030	4523	4421	4479	4516	3597	4023	3782	4643	4643	3597
28	3663	4536	3681	4498	4264	4563	4317	4393	3602	4129	3706	4235	4563	3602
29	3589	4208	3448	4460	4522	4752	4527	4156	3622	4199	4223	4247	4752	3448
30	3667	4345	3459	4256	4580	4973	4392	4148	3537	3976		4335	4973	3459
31		4473		4326	4726		4424		3655	3952		3915	4726	3655
MAX	4425	4692	4729	4498	5427	4973	5270	4522	4038	4199	4223	4643	5427	3693
MIN	3284	3330	3448	3257	4264	3800	4068	4114	3186	3496	3603	3685	4563	3186


**COMPARISON OF MONTHLY PEAK DEMAND (MW) EXCLUDING TRADING FOR THE
YEAR ENDING 2017-18 & 2018-19**



**COMPARISON OF MONTHLY ENERGY DEMAND (MU) EXCLUDING TRADING & RETURN
BANKING POWER FOR THE YEAR ENDING 2017-18 & 2018-19**

Page - 5




DEMAND CURVE FOR HOURLY AVERAGE DEMAND EXCLUDING TRADING FOR YEAR ENDING MARCH 2019


Hourly Average Demand (Month wise) in support of Page-6

Hours-->	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Apr-18	3435	3357	3299	3241	3260	3298	3158	3174	3107	3084	3155	3236	3312	3284	3383	3476	3307	3099	3270	3645	3705	3658	3583	3483
May-18	3881	3910	3766	3692	3703	3655	3556	3398	3333	3306	3345	3387	3438	3475	3634	3795	3749	3497	3558	3908	3883	3834	3799	3711
Jun-18	4128	4180	3969	3904	3895	3795	3702	3261	3106	3060	3024	2999	3026	3020	3110	3295	3301	3215	3300	3649	3655	3621	3535	3471
Jul-18	3608	3666	3458	3394	3389	3419	3397	3436	3390	3326	3274	3227	3174	3129	3158	3256	3290	3265	3513	3908	3936	3886	3779	3687
Aug-18	4279	4342	4162	4123	4149	4208	4177	4259	4257	4165	4107	4045	3985	3935	3970	4088	4106	4150	4464	4747	4756	4682	4524	4405
Sep-18	4004	4109	3885	3839	3853	3918	3897	3936	3907	3853	3809	3774	3714	3660	3668	3765	3791	3866	4328	4432	4459	4381	4258	4132
Oct-18	4270	4291	4151	4102	4132	4232	4167	4202	4145	4066	4119	4084	3988	3930	3986	4142	4217	4377	4620	4627	4563	4467	4322	4326
Nov-18	3407	3388	3306	3315	3446	3702	3726	3848	3752	3640	3618	3525	3383	3224	3212	3429	3638	3984	4232	4206	4092	3923	3662	3516
Dec-18	2535	2497	2450	2459	2602	2883	3110	3384	3278	3161	3113	2978	2818	2609	2551	2743	3016	3257	3520	3574	3424	3171	2839	2623
Jan-19	2654	2640	2578	2574	2697	2998	3305	3633	3564	3416	3356	3207	2991	2751	2637	2795	3053	3264	3661	3771	3628	3350	2994	2768
Feb-19	2843	2820	2746	2735	2837	3081	3320	3515	3464	3327	3251	3125	2956	2760	2698	2863	3062	3179	3671	3839	3723	3472	3184	2985
Mar-19	3477	3453	3363	3329	3373	3496	3552	3571	3495	3464	3454	3420	3355	3244	3277	3392	3432	3429	3850	4058	3994	3864	3717	3596
Avg. Annual	3543	3554	3428	3392	3445	3557	3589	3635	3567	3489	3469	3417	3345	3252	3274	3420	3497	3549	3832	4030	3985	3859	3683	3559

HOURLY DEMAND CURVE FOR 23.08.2018 (MAX PEAK DEMAND OF THE YEAR (2018-19))



HOURLY DEMAND CURVE FOR 17.12.2018 (MIN PEAK DEMAND OF THE YEAR 2018-19)



1 INSTALLED CAPACITY (AS ON 31.3.2019) ENERGY GENERATION / ENERGY DRAWAL BY OPTCL

SECTOR	Installed capacity (MW)	Energy Generation (incl. Aux) (MU)	Energy Drawal by GRIDCO (MU)
A. STATE SECTOR			
OHPC(Hydro)*	2008.5	6526.671	6154.320
OPGC (Thermal)	420	3139.350	2743.108
TPPS (Thermal)	460	3609.342	3214.611
TPPS (UI-OD)			9.109
IPPs			2865.667
CPP (Synchronised to OPTCL System)			468.673
Renewable Energy Including Co-gen	-		806.592
B. CENTRAL SECTOR (Orissa Share)			
Hydro	189.40		
Thermal	1203.03	-	9910.694
C. Banking Power+OA+Trading+IEX (Import)			1248.657
TOTAL DRAWAL			27421.431
D. Banking Power+OA+Trading+IEX (Export)			975.725
E. Deviation(Export)			130.318
F. Sold to Other Utilities			46.694
Net GRIDCO demand			26268.694

Export to ICCL 7.836
Export to NALCO 54.622

* Includes Orissa share from Machhkund.

2 TRANSMISSION LINES AND SUBSTATIONS

A.CIRCUIT LINES	As on	Capacity Addition	As on	Remark
	31.03.2018	in 2018-2019	1.4.2019	
400 kV line (ckt.km)	1133.404	63.468	1196.872	1.400 kV IB-Lapanga DC – 48.982ckm 2.400kV Lapanga LILO ckt-I&II on DC Towers and Multi ckt Towers(on 400 kV Meramundai - Vedanta DC) – 14.486 ckm
220kV line (ckt.km)	5950.812*	24.044	5974.856	-
132kV line (ckt.km)	6385.692	437.611	6823.303	-
B. SUBSTATIONS				
400 / 220 /132kV (nos.)	2	1	3	(Lapanga added)
400 / 220 (nos.)	1	0	1	-
220/132/33kV (nos.)	21	-1	20	(Lapanga excluded)
220/33kV (nos.)	8	2	10	Narasinghpur, Keonjhar GIS
132/33 kV (nos.)	85	7	92	Ghens, Jharsuguda, Khuntuni, Udal, Chandbali, Chikiti, Aska New
132/33/25 kV (nos.)	1	0	1	-
132/33/11 kV (nos.)	2	-1	1	(Jharsuguda excluded)
132kV Switching Stations (OPTCL)	4	0	4	-
132kV LILO Switching Stations of Industries	16	0	16	-
Total	140	8	148	-

Note: 1. *220 kV Katapali – HINDALCO DC of 28 ckm charged on 07.06.2016 added into OPTCL asset.

2. (The above data in (2) are received from O & M branch of OPTCL system.)

Capacity addition details for 220kV:

- 1.220 KV Narasinghpur LILO DC,(Bhanjanagr - Meramundai)-10.096ckm
2. 220 KV Keonjhar PG - Keonjhar SC in DC Towers-7.5ckm,
- 3.220 KV Kasipur LILO DC,(on Therubali - IndravatiCkt IV)- 6.448ckm
- 4.220 KV Katapal - HINDALCO DC of 28 ckm charged on 07.06.2016 added into OPTCL asset

Capacity addition details for 132kV:

- 1.132 KV Bargarh New- Ghens DC- 59.060ckm
- 2.132 KV Bolangir - Patnagarh DC,(DC from New Bolangir LILO Tower)-80.005 ckm
3. 132 kV Kisinga - Kisinga RTSS - 4.952 ckm
4. 132 KV Pratapsasan LILO in DC Towers,(Chandaka – Nimapara Line)-3.8 ckm
5. 132 kV Khuntuni LILO DC ,(132 KV Chainpal - ChoudwarCkt - II SC)-1.84 ckm
6. 132 kV Padampur - Dakshina Odisha 40MW Solar SC in DC Towers-9.7 ckm
7. 132 kV Banki - Nuapatana SC (in DC Towers)-21.014 ckm
8. 132 kV Muniguda - Bissamcuttack RTSS-13.85 ckm
9. 132 kV Udal LILO DC (on 132 kV Baripada - Balasore Line)-83.3 ckm
10. 132 kV Barpali - Dunguripalli RTSS-13.605 ckm
11. 132 kV Rairakhole RTSS-3.5 ckm
12. 132kV Tusura - Vento 2x40MW Solar DC-14.8 ckm
13. 132 kV Kisinga - Vento 2x40MW Solar DC-11.48 ckm
14. 132 kV Tentulikhunti - Vento 40MW Solar SC (in DC Towers)-4.192 ckm
15. 132 kV Sunabeda - Pottangi SC (in DC Towers)-33.4 ckm
16. 132 kV Sambalpur LILO DC,(Burla PH - Rairakhole - Boinda Line)-0.772 ckm
17. 132 kV Olavar - Chandbali DC-24.996 ckm
18. 132 kV Nuapada - Nuapada RTSS-4.528 ckm
19. 132 kV Digapahandi- Chikiti DC-59 ckm
20. 132 kV Aska New LILO DC (on 132 kV Aska - Chhatrapur Line)-12.4 ckm
21. 132 kV Chandaka B- Unit 8 UG Cable-11.4 ckm
22. 132 kV Betanati LILO DC-6.208 ckm

Upgraded

- 1.132 KV Bolangir - Patnagarh DC,(DC from New Bolangir LILO Tower)(-)-39.805 ckm
2. 132 kV Sambalpur 'T' SC in DC Towers,(Burla PH - Rairakhole - Boinda Line)(-)-0.386 ckm

3 PERFORMANCE OF OPTCL DURING 2018 - 19

3 A. POWER SUPPLY SECURITY

3 A.1 Load Restriction due to non-availability of Generation / Failure of generating Stations.

Duration (In Hrs)	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
3.50	12.00	6.00	0.00		21.50
0.16	0.54	0.27	0.00		0.25

* → Load restriction imposed in the State on rotation basis to curtail the demand.

3 B. TRANSMISSION SECURITY

3 B.1 Load Restriction due to non-availability of Transmission capacity

Duration (In Hrs)	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
0	0	0.00	0	0	0
0.00	0.00	0.00	0.00	0.00	0.00

3 B.2 Rescheduling of Generation due to non- availability of Transmission capacity

Duration (In Hrs)	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
0	0	0	0	0	0
0	0	0	0	0	0

3 C OVERALL PERFORMANCE

3 C-1 FREQUENCY

(i) Above 50.05 Hz

Duration (In Hrs)	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
316.78	443.30	310.95	490.22		1561.25
14.50	20.08	14.08	22.70		17.82

(ii) Maximum continuous period beyond 50.05 Hz

Duration (In Hrs)	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
1.98	1.67	2.55	1.43		2.55
0.09	0.08	0.12	0.07		0.03

(iii) Maximum Frequency occurrence

Duration Hz	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
50.25	50.23	50.17	50.29		50.29
Date/Time	<u>09.06.18</u>	<u>18.07.18</u>	<u>22.11.18</u>	<u>01.03.19</u>	<u>01.03.19</u>

(iv) Below 49.9 Hz

Duration (In Hrs)	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
273.38	150.47	206.65	178.28		808.79
12.52	6.81	9.36	8.25		9.23

(v) Maxm. Continuous period below 49.9 Hz

Duration (In Hrs)	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
2.33	1.02	1.08	0.82		2.33
0.107	0.046	0.049	0.038		0.027

(vi) Lowest Frequency Occurrence

Duration Hz	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>	<u>Annual</u>
49.6	49.6	49.72	49.59		49.59
Date/Time	<u>26.05.18</u>	<u>24.08.18</u>	<u>21.12.18</u>	<u>04.01.19</u>	<u>04.01.19</u>

3. C - 2 VOLTAGE PROFILE (2018-2019)

MAXIMUM VOLTAGES OF MAJOR GRID SUB-STATIONS. (220kV)

Sl. No.	Name of the Sub-station	Quarter - 1			Quarter - 2			Quarter - 3			Quarter - 4			ANNUAL		
		Voltage in kV	Date	Time in Hrs.												
1	ATRI	232.67	03.05.18	01:15	228.162	21.07.18	06:00	235.78	18.12.18	03:45	232.608	14.01.19	01:45	235.78	18.12.18	03:45
2	Balasore	235.55	01.04.18	21:45	232.55	21.09.18	06:00	234.11	18.12.18	03:00	231.568	02.01.19	03:00	235.55	01.04.18	21:45
3	Bhadrak	239.131	26.06.18	05:00	234.571	21.09.18	06:00	237.69	02.11.18	08:30	235.032	03.01.19	04:00	239.13	26.06.18	05:00
4	Bhanjanagar	235.437	01.04.18	23:45	235.148	21.09.18	14:15	237.69	18.12.18	03:45	235.552	22.01.19	03:45	237.69	18.12.18	03:45
5	Bidanasi	234.917	01.04.18	19:00	232.55	21.09.18	14:15	239.88	30.12.18	22:00	238.496	21.01.19	03:15	239.88	30.12.18	22:00
6	Budhipadar	231.973	27.06.18	14:30	232.896	19.08.18	04:00	233.53	18.12.18	03:30	234.34	16.01.19	03:00	234.34	16.01.19	03:00
7	Chandaka	232.954	01.04.18	23:45	234.34	21.09.18	14:15	235.32	18.12.18	03:45	232.896	21.01.19	02:00	235.32	18.12.18	03:45
8	Duburi	235.494	01.04.18	23:00	234.744	21.09.18	06:00	237.75	18.12.18	03:45	236.187	30.01.19	03:00	237.75	18.12.18	03:45
9	Jaynagar	239.882	15.05.18	04:45	238.901	23.07.18	13:00	239.77	17.12.18	05:30	237.169	22.01.19	03:45	239.88	15.05.18	04:45
10	Joda	233.243	01.04.18	19:15	234.397	31.08.18	14:30	234.34	18.12.18	06:00	235.321	16.02.19	03:45	235.32	16.02.19	03:45
11	Katapalli	231.511	01.05.18	01:00	235.148	19.08.18	04:00	232.49	18.12.18	03:30	230.067	07.01.19	16:00	235.15	19.08.18	04:00
12	Lapanga	232.723	01.05.18	01:45	235.552	19.08.18	04:00	233.7	17.12.18	13:15	232.723	16.01.19	02:15	235.55	19.08.18	04:00
13	Laxmipur	239.71	15.05.18	04:45	236.65	23.07.18	13:00	237.86	17.12.18	23:45	237.80	22.01.19	03:45	239.71	15.05.18	04:45
14	Mendhasal	234.11	01.05.18	23:45	235.21	21.09.18	14:15	238.27	18.12.18	04:00	234.63	14.01.19	01:45	238.27	18.12.18	04:00
15	Meramundai	227.873	01.04.18	23:45	227.412	07.09.18	02:15	229.37	17.12.18	03:45	228.104	07.01.19	02:00	229.37	17.12.18	03:45
16	Narendrapur	237.00	03.05.18	01:15	229.663	03.07.18	12:00	240.92	11.10.18	13:00	235.61	22.01.19	03:45	240.92	11.10.18	13:00
17	Paradeep	234.51	01.04.18	19:30	232.49	20.09.18	13:00	234.97	18.12.18	04:30	234.57	27.02.19	02:15	234.97	18.12.18	04:30
18	Sadeipali	231.80	29.06.18	12:45	231.86	22.07.18	06:00	230.99	18.12.18	03:00	228.97	16.02.19	00:45	231.86	22.07.18	06:00
19	Tarkera	247.96	01.06.18	13:00	233.36	22.07.18	17:00	230.93	18.12.18	03:30	231.74	07.01.19	02:00	247.96	01.06.18	13:00
20	Theruvali	235.78	03.05.18	05:30	232.43	15.08.18	04:00	234.51	18.12.18	03:45	234.63	22.01.19	03:45	235.78	03.05.18	05:30

MINIMUM VOLTAGES OF MAJOR GRID SUB-STATIONS. (220kV)

Sl. No.	Name of the Sub-station	Quarter - 1			Quarter - 2			Quarter - 3			Quarter - 4			ANNUAL		
		Voltage in kV	Date	Time in Hrs.												
1	ATRI	208.01	16.06.18	0.5313	210.842	29.07.18	22:30	216.27	03.10.18	20:45	207.955	29.03.19	17:00	207.96	29.03.19	17:00
2	Balasore	211.246	15.06.18	23:00	208.417	28.09.18	20:00	201	02.10.18	22:45	209.514	30.03.19	14:30	201.00	02.10.18	22:45
3	Bhadrak	210.958	14.06.18	20:30	209.11	23.08.18	20:45	207.67	02.10.18	22:45	204.03	31.03.19	14:45	204.03	31.03.19	14:45
4	Bhanjanagar	213.96	13.06.18	19:30	213.209	04.08.18	19:15	221.35	03.10.18	20:45	216.442	29.03.19	15:15	213.21	04.08.18	19:15
5	Bidanasi	212.805	09.05.18	15:30	212.863	07.08.18	08:15	219.39	20.11.18	17:45	215.345	26.02.19	18:15	212.81	09.05.18	15:30
6	Budhipadar	201.085	29.05.18	00:30	218.694	07.07.18	08:30	215.93	26.12.18	11:15	225.391	13.03.19	10:15	201.09	29.05.18	00:30
7	Chandaka	205.70	19.06.18	14:45	211.881	04.07.18	19:15	216.27	03.10.18	20:45	207.84	29.03.19	15:15	205.70	19.06.18	14:45
8	Duburi	211.593	17.04.18	18:45	216.052	04.07.18	17:30	219.39	05.10.18	19:15	218.867	30.03.19	22:30	211.59	17.04.18	18:45
9	Jaynagar	220.945	22.04.18	08:15	226.084	04.07.18	19:30	223.02	26.11.18	18:00	226.777	28.03.19	19:00	220.95	22.04.18	08:15
10	Joda	211.766	26.04.18	15:00	215.00	10.08.18	20:45	216.38	16.11.18	09:00	208.821	26.03.19	21:00	208.82	26.03.19	21:00
11	Katapalli	214.133	05.04.18	17:00	212.343	20.07.18	10:45	205.01	02.10.18	15:30	205.127	07.01.19	15:45	205.01	02.10.18	15:30
12	Lapanga	221.234	05.04.18	17:00	204.722	30.09.18	18:00	204.38	02.10.18	15:30	205.935	07.01.19	15:45	204.38	02.10.18	15:30
13	Laxmipur	219.62	13.06.18	19:45	223.89	04.07.18	19:30	225.62	10.11.18	17:45	224.64	28.03.19	19:00	219.62	13.06.18	19:45
14	Mendhasal	208.19	19.06.18	14:45	213.73	23.08.18	19:15	217.83	03.10.18	20:45	209.46	29.03.19	15:15	208.19	19.06.18	14:45
15	Meramundai	216.269	18.04.18	23:15	217.943	03.07.18	19:30	218.98	08.11.18	17:30	219.906	19.03.19	18:45	216.27	18.04.18	23:15
16	Narendrapur	205.184	13.06.18	19:30	209.226	04.08.18	19:15	209.75	06.11.18	17:45	204.203	29.03.19	15:15	204.20	29.03.19	15:15
17	Paradeep	203.91	19.06.18	22:30	203.91	23.08.18	21:00	206.80	03.10.18	20:45	206.97	28.03.19	21:00	203.91	19.06.18	22:30
18	Sadeipali	199.76	05.04.18	16:45	211.94	02.07.18	19:15	207.20	02.10.18	15:30	208.99	08.01.19	08:15	199.76	05.04.18	16:45
19	Tarkera	220.08	30.05.18	21:00	222.16	29.09.18	18:30	222.91	03.10.18	19:45	224.29	14.02.19	09:00	220.08	30.05.18	21:00
20	Theruvali	209.57	13.06.18	21:30	214.19	04.07.18	20:30	214.42	01.10.18	18:15	217.65	28.03.19	23:00	209.57	13.06.18	21:30

MAXIMUM VOLTAGES OF MAJOR GRID SUB-STATIONS. (132kV)

Sl. No.	Name of the Sub-station	Quarter - 1			Quarter - 2			Quarter - 3			Quarter - 4			ANNUAL		
		Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.
1	Cuttack	139.022	01.04.18	19:00	138.156	21.09.18	14:15	140.87	18.12.18	03:45	139.48	28.02.19	00:00	140.87	18.12.18	03:45
2	Berhampur	141.50	03.05.18	01:00	139.426	21.09.18	02:00	144.97	11.10.18	13:00	139.95	22.01.19	03:45	144.97	11.10.18	13:00
3	Puri	135.10	03.05.18	01:00	136.77	21.09.18	14:15	137.58	18.12.18	03:00	135.33	31.03.19	21:15	137.58	18.12.18	03:00
4	Khurda	137.35	13.05.18	04:15	138.04	21.09.18	14:15	138.73	18.12.18	03:45	138.1	31.03.19	21:15	138.73	18.12.18	03:45

MINIMUM VOLTAGES OF MAJOR GRID SUB-STATIONS. (132kV)


Sl. No.	Name of the Sub-station	Quarter - 1			Quarter - 2			Quarter - 3			Quarter - 4			ANNUAL		
		Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.	Voltage in kV	Date	Time in Hrs.
1	Cuttack	116.795	16.04.18	11:30	121.24	02.08.18	17:30	127.71	03.10.18	20:45	115	16.03.19	10:45	115.00	16.03.19	10:45
2	Berhampur	119.162	13.06.18	19:30	122.05	04.08.18	19:15	122.34	06.11.18	17:45	119.28	26.02.19	18:15	119.16	13.06.18	19:30
3	Puri	116.564	26.04.18	14:45	121.644	12.07.18	12:15	118.58	26.10.18	17:30	116.45	11.01.19	08:45	116.45	11.01.19	08:45
4	Khurda	121.93	31.05.18	20:30	123.90	04.08.18	19:15	125.51	05.11.18	17:45	122.16	29.03.19	14:45	121.93	31.05.18	20:30

Note:


The bus voltages are recorded from 15min block voltage from meter data .

Further, low voltages during contingency conditions are also recorded as minimum voltages excluding disturbance period and any PT failure period.

OVERALL PERFORMANCE VOLTAGE AT 220kV




OVERALL PERFORMANCE VOLTAGE AT 132 kV



Frequency Performance

Percentage time occurrence




INTERRUPTION DUE TO MAJOR INCIDENT

Incident	Duration of Interruption	No. of Interruption
Snapping of Jumper / Conductor / Earth wire	19:51:00	39
Insulator Failure	16:53:00	25
Bursting of CT / PT	4:06:00	11
Breaker Problem	0:00:00	0
Major System Disturbance	12:09:00	9
Failure of LA	7:28:00	10
Others	81:35:00	172

The duration of interruption indicated above is the sum total of interruptions occurred at different areas(S/s) during the year. However there was no total blackout experienced for the State during the year 2018-19.

INTERRUPTION (HRS) DUE TO MAJOR INCIDENT DURING 2018-19



- Snapping of Jumper / Conductor / Earth wire
- Insulator Failure
- Bursting of CT / PT
- Breaker Problem
- Major System Disturbance
- Failure of LA
- Others



पावर मैप

POWER MAP OF EASTERN REGION

