

EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH MAY-2026(R-0)

EXPORT TTC/ATC

SL. No.	Control Area	Month	Export TTC	Reliability Margin	Counterflow on Surrender of ISGS	Export ATC	Contingency	Assumptions
1	Odisha	May-26	1701	131 (2% of load assumed)	0	1570	Outage of one 210MW Generator of IBTPS Stage-1	Generation:6533 MW Load: 4701 MW

IMPORT TTC/ATC

SL. No.	Control Area	Month	Import TTC	Reliability Margin	Approved GNA	Import ATC	Contingency	Assumptions
1	Odisha(excluding Vedanta)	May-26	3016	134 (2% of load assumed)	2157	725	NIL	Generation: 4084 MW Load: 6700 MW
2	Vedanta		1600	32 (2% of load assumed)	NIL	1568		Load: 1600 MW

Total Import TTC for Odisha Control Area = 3016 MW+ 1600 MW = 4616 MW

* All figures are in MW