

## EXPORT & IMPORT TTC/ATC OF OPTCL SYSTEM FOR THE MONTH JUNE-2026(R-0)

### EXPORT TTC/ATC

| SL. No. | Control Area | Month  | Export TTC | Reliability Margin         | Counterflow on Surrender of ISGS | Export ATC | Contingency                                    | Assumptions                         |
|---------|--------------|--------|------------|----------------------------|----------------------------------|------------|------------------------------------------------|-------------------------------------|
| 1       | Odisha       | Jun-26 | 1700       | 96<br>(2% of load assumed) | 0                                | 1604       | Outage of one 210MW Generator of IBTPS Stage-1 | Generation:6621 MW<br>Load: 4800 MW |

### IMPORT TTC/ATC

| SL. No. | Control Area              | Month  | Import TTC | Reliability Margin          | Approved GNA | Import ATC | Contingency | Assumptions                          |
|---------|---------------------------|--------|------------|-----------------------------|--------------|------------|-------------|--------------------------------------|
| 1       | Odisha(excluding Vedanta) | Jun-26 | 3024       | 134<br>(2% of load assumed) | 2157         | 733        | NIL         | Generation: 3911 MW<br>Load: 6700 MW |
| 2       | Vedanta                   |        | 1600       | 32<br>(2% of load assumed)  | NIL          | 1568       |             | Load: 1600 MW                        |

Total Import TTC for Odisha Control Area = 3024 MW+ 1600 MW = 4624 MW

\* All figures are in MW